



PROGRESS IN MOTION

**CITY OF FRISCO PURCHASING DIVISION**

March 11, 2015

Addendum #3 – Clarifications

CSB #1503-046 Frisco 1 North Vertical Turbine Pump

**Clarifications**

The top flange bolt hole pattern should be drilled to ANSI B16.1 class 125 flanges. This standard flange dimension has 28 holes on 36" bolt hole circle that any manufacturer can fit their head to the barrel if pumps need to be changed in the future.

-Discharge Head material may be cast iron steel or fabricated steel.

**The bid due date was previously extended to Thursday, March 19, 2015 by 2:00pm CST.  
This date remains unchanged.**

Bidders are required to acknowledge receipt of this addendum by initialing in the appropriate space on the bid document. The due date for this CSB is Thursday, March 19, 2015 by 2:00pm CST.

Vendors who may have already submitted a bid and feel this addendum may change their bid, may pick up their bid, and return it by the closing date. If picking up the bid is not feasible, any new bid submitted by your firm will supersede one previously submitted. If there is a discrepancy between this addendum and the bid, the addendum prevails.

Sincerely,

Daniel Ford, CPPO, CPPB  
Purchasing Manager  
City of Frisco